



Émissions de formaldéhyde

Dans le cadre de la législation européenne sur les produits chimiques et du règlement REACH en vigueur (Règlement (CE) n° 1907/2006 et des restrictions spécifiques relatives au formaldéhyde), nos portes intérieures ont été testées quant à leurs émissions de formaldéhyde. Cette fiche technique présente les résultats d'essais certifiés, tant pour les portes à peindre que pour les portes HPL.

1 Résultats d'essais

Les essais d'émission ont été réalisés conformément aux normes européennes en vigueur. Les résultats démontrent que les valeurs d'émission sont nettement inférieures aux seuils réglementaires.

Valeur limite européenne (REACH 2026): 0,062 mg/m ³			
Type de porte	Émission mesurée	Conclusion	Rapport d'essai
Porte à peindre	0,004 mg/m ³	Conform REACH 2026	RP26-0025
Porte HPL	0,002 mg/m ³	Conform REACH 2026	RP26-0049

2 Domaine d'application

- **REACH- conformité:** Les valeurs mesurées sont conformes aux restrictions européennes concernant les émissions de formaldéhyde des produits à base de bois en intérieur.
- **BREEAM & WELL:** Les valeurs d'émission de ces vantaux conviennent aux projets ayant des exigences en matière de qualité de l'air intérieur, telles que prescrites par BREEAM (Hea 02) et le WELL Building Standard.



WOOD.BE

Reference: AT_RP-26-0025_DE COENE PRODUCTS_B_REACH_260428_E

REACH: TEST ATTESTATION

with reference to RP-26-0025

Customer: DE COENE PRODUCTS
Europalaan 135
8560 Wevelgem
Belgium

Date: 28/04/2026

Subject: Formaldehyde release test according to the applicable standard

Product Name⁽¹⁾: Samengekleefd deurpaneel DCP ATG3244 type 2 schilderdeur + multiplex omlijsting

Reference documents: NBN EN717-1 (Wood-based panels - Determination of formaldehyde release - Part 1: Formaldehyde emission by the chamber method)
Commission Regulation (EU) 2023/1464 Appendix 14

Loading Factor: 1 unit (EN717-1 REACH appendix 14)

Results: 0,004 mg/m³

Evaluation: The result of the tested samples is below the limit value of 0,062 mg/m³ according to EU regulations.
This product, as tested in RP-26-0025 is REACH-compliant.

Brussels,

Ing. R. Van Pestel
Lab Manager

(1) Information communicated by the customer
The results only relate to the tested samples.
Unless stated otherwise, the mentioned standards refer to the latest active version of these standards.

FO-08-B01-13 (29/01/2025)

Allée Hof ter Vleestdreef 3 - B-1070 Brussels - T: 00 32 2 558 15 50
info@wood.be – www.wood.be

TVA BE 0406.676.656 BTW



WOOD.BE

Reference: AT_RP-26-0049_DE COENE PRODUCTS_B_REACH_260507_E

REACH: TEST ATTESTATION

with reference to RP-26-0049

Customer: DE COENE PRODUCTS
Europalaan 135
8560 Wevelgem
Belgium

Date: 07/05/2026

Subject: Formaldehyde release test according to the applicable standard

Product Name⁽¹⁾: Samengekleefd deurpaneel DCP ATG3244 type 2 HPL deur + meranti omlijsting

Reference documents: NBN EN717-1 (Wood-based panels - Determination of formaldehyde release - Part 1: Formaldehyde emission by the chamber method)
Commission Regulation (EU) 2023/1464 Appendix 14

Loading Factor: 1 unit (EN717-1 REACH appendix 14)

Results: 0,002 mg/m³

Evaluation: The result of the tested samples is below the limit value of 0,062 mg/m³ according to EU regulations.
This product, as tested in RP-26-0049 is REACH-compliant.

Brussels,



Ing. R. Van Pestel
Lab Manager

(1) Information communicated by the customer
The results only relate to the tested samples.
Unless stated otherwise, the mentioned standards refer to the latest active version of these standards.

FO-08-B01-13 (29/01/2026)

Allée Hof ter Vleestdreef 3 - B-1070 Brussels - T: 00 32 2 558 15 50
info@wood.be – www.wood.be

TVA BE 0406.676.656 BTW